

今夏の電力需給の当日予想と実績(平成27年7月)

(単位:万kW)

	月		火		水		木		金		土		日	
当日 予想					1	80%	2	82%	3	84%	4	82%	5	81%
	需 1,830		需 1,900		需 1,900		需 1,700		需 1,540					
	供 2,277		供 2,297		供 2,241		供 2,055		供 1,889					
実績 (確報値)	81%		81%		83%		77%		82%					
	1,862(10時-11時)		1,869(14時-15時)		1,880(14時-15時)		1,589(11時-12時)		1,549(19時-20時)					
トピックス														
当日 予想	6	77%	7	77%	8	82%	9	87%	10	86%	11	80%	12	83%
	需 1,810		需 1,760		需 1,910		需 2,010		需 2,110		需 1,930		需 1,890	
	供 2,342		供 2,281		供 2,309		供 2,304		供 2,426		供 2,406		供 2,269	
実績 (確報値)	74%		79%		82%		88%		88%		78%		84%	
	1,745(11時-12時)		1,815(11時-12時)		1,910(14時-15時)		2,044(16時-17時)		2,143(14時-15時)		1,893(13時-14時)		1,920(19時-20時)	
トピックス														
当日 予想	13	91%	14	89%	15	83%	16	82%	17	87%	18	74%	19	79%
	需 2,300		需 2,350		需 2,270		需 2,150		需 2,080		需 1,810		需 1,770	
	供 2,527		供 2,614		供 2,703		供 2,619		供 2,370		供 2,414		供 2,229	
実績 (確報値)	90%		89%		86%		82%		83%		72%		80%	
	2,297(16時-17時)		2,334(14時-15時)		2,337(16時-17時)		2,152(13時-14時)		1,969(11時-12時)		1,745(19時-20時)		1,790(19時-20時)	
トピックス														
当日 予想	20	84%	21	85%	22	84%	23	83%	24	84%	25	78%	26	79%
	需 1,970		需 2,330		需 2,110		需 2,110		需 2,160		需 2,020		需 1,970	
	供 2,343		供 2,716		供 2,486		供 2,535		供 2,568		供 2,560		供 2,469	
実績 (確報値)	81%		80%		81%		77%		85%		78%		79%	
	1,911(16時-17時)		2,178(14時-15時)		2,030(11時-12時)		1,971(11時-12時)		2,204(14時-15時)		1,998(16時-17時)		1,954(19時-20時)	
トピックス														
当日 予想	27	78%	28	79%	29	81%	30	82%	31	88%				
	需 2,270		需 2,290		需 2,360		需 2,380		需 2,480					
	供 2,889		供 2,879		供 2,889		供 2,868		供 2,791					
実績 (確報値)	80%		81%		82%		83%		90%					
	2,340(13時-14時)		2,348(14時-15時)		2,383(16時-17時)		2,383(16時-17時)		2,524(16時-17時)					
トピックス														

※姫路第二発電所は、蒸気タービンの不具合事象を踏まえ、6月3日から3号機試運転開始の7月8日まで全台停止

※当日予想 ・需…当日の予想最大電力
 ・供…当日のピーク時供給力
 ※実績 ・当日の最大使用率と最大電力(1時間間値・確報値)

今夏の電力需給の当日予想と実績(平成27年8月)

(単位:万kW)

	月		火		水		木		金		土		日	
当日 予想											1	78%	2	78%
	需 2,200		需 2,510		需 2,520		需 2,570		需 2,530		需 2,250		需 2,110	
	供 2,785		供 2,902		供 2,864		供 2,854		供 2,839		供 2,881		供 2,673	
実績 (確報値)	81%		80%								81%		80%	
	2,277(14時-15時)		2,556(16時-17時)		2,548(16時-17時)		2,468(14時-15時)		2,527(16時-17時)		2,340(14時-15時)		2,089(19時-20時)	
トピックス														
当日 予想	3	91%	4	86%	5	87%	6	90%	7	89%	8	78%	9	78%
	需 2,540		需 2,510		需 2,520		需 2,570		需 2,530		需 2,250		需 2,140	
	供 2,781		供 2,902		供 2,864		供 2,854		供 2,839		供 2,881		供 2,736	
実績 (確報値)	91%		88%		88%		86%		89%		81%		76%	
	2,536(15時-16時)		2,556(16時-17時)		2,548(16時-17時)		2,468(14時-15時)		2,527(16時-17時)		2,340(14時-15時)		2,089(19時-20時)	
トピックス														
当日 予想	10	88%	11	80%	12	80%	13	79%	14	75%	15	80%	16	78%
	需 2,590		需 2,280		需 2,100		需 1,870		需 1,780		需 1,830		需 1,850	
	供 2,938		供 2,846		供 2,621		供 2,363		供 2,346		供 2,264		供 2,368	
実績 (確報値)	80%		78%		74%		75%		75%		80%		73%	
	2,377(14時-15時)		2,244(14時-15時)		1,960(15時-16時)		1,788(19時-20時)		1,777(19時-20時)		1,827(19時-20時)		1,743(18時-19時)	
トピックス	姫二6号機通常運転開始													
当日 予想	17	77%	18	78%	19	76%	20	76%	21	78%	22	76%	23	77%
	需 2,050		需 2,190		需 2,160		需 2,100		需 2,150		需 2,050		需 1,880	
	供 2,655		供 2,804		供 2,818		供 2,743		供 2,751		供 2,684		供 2,421	
実績 (確報値)	78%		77%		71%		74%		80%		72%		73%	
	2,093(14時-15時)		2,181(16時-17時)		2,011(11時-12時)		2,048(16時-17時)		2,201(14時-15時)		1,935(11時-12時)		1,785(19時-20時)	
トピックス														
当日 予想	24	78%	25	78%	26	78%	27	83%	28	89%	29	85%	30	77%
	需 2,250		需 2,050		需 2,150		需 2,130		需 2,110		需 1,880		需 1,660	
	供 2,868		供 2,608		供 2,752		供 2,560		供 2,347		供 2,210		供 2,149	
実績 (確報値)	74%		78%		74%		82%		90%		82%		78%	
	2,127(16時-17時)		2,036(10時-11時)		2,053(15時-16時)		2,120(16-17時)		2,135(14時-15時)		1,834(13時-14時)		1,695(18時-19時)	
トピックス														
当日 予想	31	83%												
	需 2,020													
	供 2,424													
実績 (確報値)	77%													
	1,878(11時-12時)													
トピックス														

※当日予想 ・需…当日の予想最大電力
 ・供…当日のピーク時供給力

※実績 ・当日の最大使用率と最大電力(1時間値・確報値)

今夏の電力需給の当日予想と実績(平成27年9月)

(単位:万kW)

	月		火		水		木		金		土		日	
当日 予想			1	84%	2	87%	3	84%	4	88%	5	75%	6	71%
	需 1,960		需 2,040		需 1,910		需 1,960		需 1,720		需 1,580			
	供 2,320		供 2,338		供 2,265		供 2,217		供 2,275		供 2,197			
実績 (確報値)	89%		84%		84%		86%		73%		72%			
	2,068(14時-15時)		1,978(14時-15時)		1,915(10時-11時)		1,918(16時-17時)		1,677(18時-19時)		1,594(18時-19時)			
トピックス														
当日 予想	7	77%	8	85%	9	84%	10	78%	11	80%	12	75%	13	75%
	需 1,870		需 1,830		需 1,840		需 1,810		需 1,820		需 1,600		需 1,560	
	供 2,418		供 2,132		供 2,174		供 2,307		供 2,271		供 2,106		供 2,080	
実績 (確報値)	73%		85%		82%		79%		76%		76%		74%	
	1,785(18時-19時)		1,820(16時-17時)		1,785(18時-19時)		1,845(10時-11時)		1,744(16時-17時)		1,610(18時-19時)		1,555(18時-19時)	
トピックス														
			海南2号機発電停止						海南2号機復旧					
当日 予想	14	82%	15	86%	16	89%	17	86%	18	87%	19	85%	20	82%
	需 1,770		需 1,740		需 1,760		需 1,720		需 1,730		需 1,510		需 1,450	
	供 2,141		供 2,018		供 1,957		供 1,978		供 1,967		供 1,772		供 1,764	
実績 (確報値)	80%		89%		90%		88%		87%		85%		84%	
	1,732(18時-19時)		1,802(18時-19時)		1,762(11時-12時)		1,745(10時-11時)		1,721(11時-12時)		1,513(18時-19時)		1,491(18時-19時)	
トピックス														
当日 予想	21	82%	22	80%	23	87%	24	83%	25	82%	26	77%	27	78%
	需 1,500		需 1,560		需 1,650		需 1,780		需 1,780		需 1,580		需 1,580	
	供 1,813		供 1,926		供 1,885		供 2,127		供 2,169		供 2,033		供 2,012	
実績 (確報値)	85%		83%		87%		81%		81%		79%		77%	
	1,542(18時-19時)		1,610(18時-19時)		1,654(18時-19時)		1,730(10時-11時)		1,765(17時-18時)		1,618(11時-12時)		1,556(18時-19時)	
トピックス														
当日 予想	28	80%	29	79%	30	77%								
	需 1,740		需 1,730		需 1,710									
	供 2,154		供 2,165		供 2,199									
実績 (確報値)	81%		79%		74%									
	1,753(18時-19時)		1,715(18時-19時)		1,644(18時-19時)									
トピックス														
			姫二5号機通常運転開始											

※当日予想 ・需…当日の予想最大電力
 ・供…当日のピーク時供給力

※実績 ・当日の最大使用率と最大電力(1時間値・確報値)