

出力時出力分布測定検査記録 (75%出力時)

	R	P	N	M	L	K	J	H	Q	F	E	D	C	B	A
1					0.882	1.099	0.803	1.071	0.816	1.120	0.896				
2				0.513	0.504	1.214	1.176	0.970	1.280	0.989	1.189	1.219	0.492	0.506	
3			0.501	0.501	1.234	1.146	0.982	1.271	0.968	1.205	1.239	0.502	0.511		
4			0.5	0.5	-1.4	-1.7	-1.1	-0.9	-0.9	-1.3	-1.6	-2.1	-1.0		
5			0.501	0.502	1.165	1.212	0.982	1.314	1.176	1.319	0.982	1.208	1.141	0.537	0.512
6			0.509	0.802	1.166	1.252	0.989	1.325	1.182	1.332	1.005	1.234	1.165	0.635	0.512
7			-1.7	-1.6	-0.2	-1.4	-1.7	-0.8	-0.5	-1.0	-2.2	-2.1	-2.1	-1.1	0.0
8			0.497	1.154	1.101	1.280	1.051	1.180	1.286	1.179	0.982	1.008	1.152	0.498	
9			0.502	1.163	1.008	1.268	0.991	1.182	1.280	1.184	0.983	1.265	1.001	1.166	0.503
10			-2.9	-2.5	0.1	1.0	1.0	-0.2	0.1	-0.4	-0.4	-1.1	-1.2	-1.4	-1.1
11	0.889	1.225	1.210	1.365	1.301	1.160	0.895	0.806	0.804	1.15	1.297	1.561	1.215	1.219	0.889
12	0.901	1.239	1.223	1.365	1.284	1.145	0.895	0.806	0.898	1.145	1.265	1.371	1.237	1.241	0.901
13	-1.3	-1.1	-1.5	-0.1	1.3	1.4	0.0	-0.3	-0.3	0.5	0.5	-0.7	-1.5	-1.8	-1.3
14	1.146	1.213	0.957	0.980	1.132	1.045	0.844	0.764	0.948	1.049	1.158	0.983	0.885	1.184	1.111
15	1.127	1.205	1.005	0.982	1.145	1.039	0.844	0.767	0.945	1.039	1.148	0.994	1.005	1.205	1.128
16	1.7	0.6	-0.8	-0.2	0.3	0.8	0.0	-0.4	0.4	1.0	1.1	-1.1	-1.0	-1.7	-1.3
17	0.835	1.004	1.026	1.177	0.893	0.839	0.466	0.382	0.470	0.849	0.997	1.181	1.025	0.952	0.811
18	0.825	1.000	1.001	1.184	0.899	0.844	0.470	0.389	0.470	0.844	0.899	1.184	1.032	0.967	0.825
19	1.0	0.4	-0.4	-0.2	-0.3	-0.3	-0.0	-1.7	0.1	0.2	0.2	-0.3	-0.5	-0.6	-0.7
20	1.091	1.277	1.180	1.278	0.759	0.742	0.360	0.290	0.367	0.770	0.812	1.260	1.183	1.277	1.094
21	1.094	1.279	1.186	1.285	0.809	0.765	0.368	0.295	0.367	0.766	0.805	1.260	1.183	1.278	1.094
22	-0.3	-0.1	-0.5	-0.5	-1.2	-1.3	-2.4	-1.5	0.1	0.5	0.5	0.3	-0.2	-0.1	0.0
23	0.820	0.985	1.328	1.188	0.846	0.841	0.468	0.383	0.467	0.847	0.981	1.197	1.339	1.004	0.825
24	0.823	0.988	1.332	1.185	0.844	0.844	0.469	0.386	0.468	0.843	0.985	1.183	1.334	1.000	0.825
25	-0.3	-0.2	-0.3	0.3	0.0	-0.4	-1.0	-0.8	-0.2	0.4	0.7	1.1	0.8	0.4	0.0
26	1.130	1.211	0.984	1.004	1.180	1.052	0.851	0.768	0.943	1.053	1.165	1.010	1.021	1.228	1.149
27	1.126	1.206	1.005	0.994	1.149	1.003	0.844	0.766	0.943	1.005	1.144	0.992	1.005	1.206	1.127
28	0.8	0.5	-1.0	1.0	1.2	1.3	0.8	0.5	0.0	1.4	2.0	1.9	1.8	1.8	2.0
29	0.920	1.256	1.238	1.385	1.290	1.139	0.902	0.812	0.895	1.160	1.310	1.392	1.253	1.264	0.904
30	0.901	1.241	1.237	1.378	1.282	1.149	0.898	0.800	0.805	1.144	1.304	1.385	1.239	1.230	0.900
31	2.1	2.0	0.1	1.1	1.1	1.1	0.7	0.4	0.0	1.4	2.0	1.9	1.7	1.6	3.7
32	0.901	1.138	1.002	1.271	0.989	1.189	1.189	1.290	1.189	1.00	1.385	1.22	1.197	0.921	
33	0.503	1.169	1.101	1.266	0.983	1.184	1.295	1.182	0.98	1.365	0.99	1.163	0.902		
34	-0.5	-2.8	-0.1	0.3	0.3	1.0	0.8	0.6	1.1	2.0	2.1	2.9	4.0		
35	0.507	0.597	1.155	1.271	1.000	1.237	1.185	1.333	0.989	1.22	1.162	0.609	0.321		
36	0.512	0.503	1.165	1.234	1.005	1.231	1.182	1.325	0.989	1.232	1.168	0.602	0.508		
37	-0.8	-1.0	-0.8	0.0	-0.4	0.4	0.2	0.8	0.0	-0.2	-0.4	1.1	4.4		
38	0.908	0.500	1.241	1.201	1.003	1.270	0.901	1.197	1.221	0.889	0.515				
39	0.511	0.502	1.239	1.205	0.998	1.271	0.981	1.198	1.234	0.501	0.510				
40	-0.5	-0.3	0.2	-0.3	0.4	0.6	1.0	0.1	-1.1	-2.4	0.8				
41			0.510	1.128	0.829	1.089	0.825	1.119	0.848						
42			0.900	1.128	0.822	1.087	0.815	1.112	0.848						
43			1.1	0.0	0.1	0.2	0.8	0.1	-1.0						

← 相対出力測定値
← 相対出力第一値
← 相対出力第二値